



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

July 31, 2013

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF REISSUANCE OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Centerfield Regional Culinary Water Treatment Plant
MAILING ADDRESS: P. O Box 220200, Centerfield, UT 84622
TELEPHONE NUMBER: 435-528-3296
FACILITY LOCATION: 1600 North Highway 137, Mayfield, UT 84643
UPDES PERMIT NO.: UT0025704
PERMITTED OUTFALLS 001
RECEIVING WATER: Twelve Mile Creek

BACKGROUND

Centerfield City presently operates a culinary water system, some sources to which have nitrate concentrations that exceed the 10 mg/L maximum for drinking water standards. Centerfield City intends to operate a small reverse osmosis plant for the purpose of providing a pure water source to blend with other sources with elevated nitrate levels.

PUBLIC COMMENTS

Public comments are invited any time prior to close of business August 30, 2013. Comments may be directed to the Department of Environmental Quality, Division of Water Quality, 195 North 1950 West, P.O. Box 144870, Salt Lake City, Utah 84114-4870.

FURTHER INFORMATION

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-538-9489. Written public comments can be submitted to: Matthew Garn, Utah Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mgarn@utah.gov. The deadline to receive comments is the close of business August 30, 2013. After considering public comment the Utah Water Quality Division Director may execute the permit renewal, revise it, or abandon it.