

MODULE III CONTAINERS

III.A. PERMITTED CONTAINER STORAGE AREAS

III.A.1. Reserved.

III.A.2. Reserved.

III.A.3. Reserved.

III.A.4. The S-2 Warehouse shall be limited to the storage of site-generated wastes with the following waste codes: D001 through D011, D018, D019, D021, D022, D035, D039, D040, D043, F001 through F005, U002, U003, U037, U044, U080, U131, U154, U159, U210, U220, F999.

III.A.5. Reserved.

III.A.6. Reserved.

III.A.7. In addition to treatment explicitly allowed within this permit, the Permittee may treat the contents of a hazardous waste (HW) container provided:

- a. The Permittee is the generator of the hazardous waste (i.e., the waste was generated at a facility with the EPA I.D. Number UT5210090002).
- b. The HW container resides within the S-2 Warehouse.
- c. The treatment consists of the addition of 1) decontamination solution for the purpose of reducing the level of agent contamination, or 2) absorbent material for the purpose of absorbing free liquids.
- d. The treatment does not result in elimination of any applicable hazardous waste codes.

III.B. RESERVED

III.C. PERMITTED AND PROHIBITED WASTE IN THE CONTAINER STORAGE AREAS

III.C.1. Reserved.

III.C.2. Reserved.

III.C.3. Reserved.

III.C.4. Reserved.

III.C.5. Reserved.

III.C.6. Reserved.

III.C.7. The Permittee shall store site-generated wastes in containers in the S-2 Warehouse subject to the terms of this Permit, provided that the maximum volume of containerized waste stored in the S-2 Warehouse does not exceed 38,720 gallons.

III.C.8 The Permittee shall not exceed a maximum volume of 600 gallons of containerized waste per secondary containment pallet in the S-2 Warehouse at any one time. Except as provided in Attachment 12, the volume of a single container stored on a secondary containment pallet in the S-2 Warehouse shall not exceed 60 gallons.

III.C.9 Reserved.

III.D. **CONDITION OF CONTAINERS**

III.D.1. If a container holding hazardous waste is not in good condition (e.g., severe rusting, apparent structural defects) or if it begins to leak, the Permittee shall transfer the hazardous waste from such container to a container that is in good condition or otherwise manage the waste in compliance with the conditions of this Permit.

III.E. **COMPATIBILITY OF WASTE WITH CONTAINERS**

III.E.1. The Permittee shall comply with R315-8-9.3.

III.F. **MANAGEMENT OF CONTAINERS**

III.F.1. In the S-2 Warehouse the Permittee shall keep all containers closed except when adding or removing waste, periodically monitoring the vapor space within the container, or adding decontaminant or absorbent for the purpose of treating the contents as allowed by Condition III.A.7., and shall not handle or store containers in a manner which may rupture a container or cause it to leak.

III.F.2. The Permittee shall manage all hazardous waste placed in containers stored in permitted container storage areas in accordance with Module X.

III.G. **RESERVED**

III.H. **INSPECTION SCHEDULES AND PROCEDURES**

III.H.1. The Permittee shall inspect the container areas weekly, in accordance with the Inspection Plan (Attachment 5) and Module X, to detect leaking containers and deterioration of containers and the containment system caused by corrosion and other factors.

III.I. **RECORDKEEPING**

III.I.1. The Permittee shall document all waste received at the TOCDF in the Operating Record, in accordance with Condition II.I.

III.J. **CLOSURE**

III.J.1. At closure of the container area, the Permittee shall remove all hazardous waste and hazardous waste constituents from the containment system, in accordance with the procedures in the Closure Plan (Attachment 10).

III.K. **REACTIVE WASTES**

III.K.1. The Permittee shall take precautions to prevent accidental reaction of wastes and follow the procedures specified in Attachments 8 (Preparedness and Prevention) and 12 (Containers).

III.L. **INCOMPATIBLE WASTE**

III.L.1. In the S-2 Warehouse the Permittee shall not place containers with incompatible site-generated waste on a secondary containment pallet at the same time.