



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

November 21, 2013

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-104 AND 107, UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO UPDES PERMIT AND THE STATEMENT OF BASIS (INCLUDING THE TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303 (d) OF THE FEDERAL CLEAN WATER ACT (CWA).

PERMIT INFORMATION

PERMITTEE NAME: Fairview City
MAILING ADDRESS: P.O. Box 97, Fairview, UT 84629
TELEPHONE NUMBER: 435-427-3858
FACILITY LOCATION: 1¼ Miles South of Fairview along Hwy 89
UPDES PERMIT NO.: UTL025542
PERMITTED OUTFALLS 001
RECEIVING WATER: San Pitch River

BACKGROUND

Fairview City completed construction of a new wastewater treatment plant in late July 2005 and started discharging. The facility has a design capacity of 0.3 million gallons per day (MGD). It is a Membrane Bioreactor wastewater treatment system, serving a population of approximately 1650. The permit contains Biosolids and Storm Water components

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on December 23, 2013. Written public comments can be submitted to: Dan Griffin, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dgriffin@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

FURTHER INFORMATION

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Dan Griffin at 801-536-4387.