



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

January 23, 2017

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to renew a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Holliday Water Company
MAILING ADDRESS: 1887 East 4700 South, Salt Lake City, UT 84117
TELEPHONE NUMBER: 801-277-2893
FACILITY LOCATION: 2889 East Live Oak Circle, Holliday, UT 84117
UPDES PERMIT NO.: UT0025429
PERMITTED OUTFALLS: 001
RECEIVING WATER: North Fork of Spring Creek then to a storm drain on Holliday Boulevard

BACKGROUND

The Holliday Water Company is a culinary water treatment plant located at 2889 E. Live Oak Circle (approximately 4590 South) in Salt Lake County. The plant has a gross capacity of 2.5 million gallons per day (MGD) of drinking water and processes spring water through microfiltration. The plant receives its water from nearby surface springs that also provide water for both the north and south forks of Spring Creek. The flow unutilized by the plant is used downstream for irrigation and aesthetic purposes. The renewal permit includes the addition of quarterly effluent monitoring requirements for copper, nickel, lead, and chromium.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on February 23, 2017. Written public comments can be submitted to: Mike Herkimer, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mherkimer@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Mike Herkimer at 801-536-4386.