



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of
Environmental Quality

Amanda Smith
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

September 11, 2013

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO ISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Santaquin Wastewater Reclamation Facility
MAILING ADDRESS: 275 West Main Street, Santaquin, Utah 84655
TELEPHONE NUMBER: 801-754-3211
FACILITY LOCATION: 1215 North Center Street, Santaquin, Utah 84655
UPDES PERMIT NO.: UT0026000
PERMITTED OUTFALLS 001R

BACKGROUND

Santaquin is constructing a membrane bioreactor (MBR) plant that will replace the existing lagoon system. The reclaimed water produced by the MBR will meet Type I reuse standards and will be utilized in the City's existing pressurized irrigation system during the irrigation season and will be stored in the existing winter storage ponds during the winter months. Off spec water that does not meet Type I reuse standards will be discharged to an existing pond with a capacity of 1.6 million gallons and recirculated through the treatment system. The SWRF will treat all of the municipal wastewater in Santaquin City. The new treatment facility will have a design flow rate of 1.0 MGD and will not discharge to waters of the State.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on October 14, 2013. Written public comments can be submitted to: Kim Shelley, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: kshelley@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Kim Shelley at 801-536-4385.