



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

October 6, 2016

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to issue a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: South Davis Sewer District-South Plant
MAILING ADDRESS: P.O. Box 140111, Salt Lake City, UT 84114-0111
TELEPHONE NUMBER: 801-936-8005
FACILITY LOCATION: 1380 West Center Street, North Salt City, UT 84054
UPDES PERMIT NO.: UT0021628
PERMITTED OUTFALLS: 001
RECEIVING WATER: Jordan River

BACKGROUND

The South Davis Sewer District South Plant (SDSDS) serves the cities of North Salt Lake, Woods Cross and a portion of Bountiful with a daily average design flow of 4 million gallons per day (MGD) and a design population equivalent of 27,000. The facility functions in a two-stage trickling filter mode. Unit operations and processes include influent pumping, screening, grit removal, primary, intermediate and secondary clarification and biological processing using trickling filters, chlorination and dechlorination prior to release into the Jordan River. Sludge generated during unit processes is stabilized in two-stage mesophilic anaerobic digesters and dried in drying beds.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on November 7, 2016. Written public comments can be submitted to: Matthew Garn, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mgarn@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.

195 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 536-4300 • Fax (801) 536-4301 • T.D.D. (801)903-3978
www.deq.utah.gov

Printed on 100% recycled paper