



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

September 21, 2016

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF REISSUANCE OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to reissue a Utah Pollutant Discharge Elimination System (UPDES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: South Valley Water Reclamation Facility
MAILING ADDRESS: 7495 South 1300 West, Salt Lake City, UT 84084
TELEPHONE NUMBER: (801) 566-7711
FACILITY LOCATION: 7495 South 1300 West, Salt Lake City, UT 84084
UPDES PERMIT NO.: UT0024384
OUTFALLS: 001
RECEIVING WATERS: Jordan River

BACKGROUND

The South Valley Water Reclamation Facility (SVWRF) serves the communities of Midvale, West Jordan, Midvalley Improvement District (Cottonwood Heights), Sandy Suburban Improvement District (Sandy), South Valley Sewer District (South Jordan, Draper, Riverton, Bluffdale, Copperton) and other unincorporated areas of Salt Lake County. The UPDES permit consists of discharge, pretreatment, biosolids, and storm water components. The Facility is located at 7495 South 1300 West in Midvale, Salt Lake County, Utah. The plant design flow capacity is 50 MGD with a peak flow of 85.5 MGD. Currently the flow is averaging around 25 MGD.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on October 21, 2016. Written public comments can be submitted to: Daniel Griffin, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dgriffin@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Daniel Griffin at 801-536-4387.

DWQ-2015-015284

288 North 1460 West • Salt Lake City, UT
Mailing Address: P.O. Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 538-6146 • Fax (801) 538-6016 • T.D.D. (801) 903-3978

www.deq.utah.gov

Printed on 100% recycled paper